

Town: BARTLETT

EPA Id: NH 0162300

System Name: ATTITASH WOODS CONDO ASSOC

Pop Served: 135

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200019	FLUORIDE	MCL VIOLATION	4.00000	4.58000000	07/03/2002	

EPA Id: NH 0162250

System Name: BARTLETT PLACE

Pop Served: 72

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200005	FLUORIDE	MCL VIOLATION	4.00000	4.21000000	05/22/2002	

EPA Id: NH 0162340

System Name: BEAR VILLAGE SOUTH

Pop Served: 30

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200013	FLUORIDE	MCL VIOLATION	4.00000	4.25000000	05/07/2002	

EPA Id: NH 0162090

System Name: LINDERHOF MOUNTAINSIDE

Pop Served: 638

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300021	FLUORIDE	MCL VIOLATION	4.00000	6.80000000	10/24/2002	06/05/2003

EPA Id: NH 0162230

System Name: PARTRIDGE WOODS CONDOMINIUMS

Pop Served: 120

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200015	BERYLLIUM	MCL VIOLATION	0.00400	0.00430000	05/13/2002	

EPA Id: NH 0162100

System Name: RIVERSBEND

Pop Served: 48

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200010	FLUORIDE	MCL VIOLATION	4.00000	4.69000000	07/03/2002	

EPA Id: NH 0162290

System Name: ROCKY RIVER RESORT

Pop Served: 100

PWS Type: COMMUNITY SYSTEM

Town: BARTLETT

EPA Id: NH 0162290

System Name: ROCKY RIVER RESORT

Pop Served: 100

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200004	FLUORIDE	MCL VIOLATION	4.00000	4.48000000	05/13/2002	

EPA Id: NH 0162130

System Name: ROLLING RIDGE

Pop Served: 83

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200010	BERYLLIUM	MCL VIOLATION	0.00400	0.01470000	04/04/2002	
200011	FLUORIDE	MCL VIOLATION	4.00000	4.10000000	04/04/2002	

EPA Id: NH 0162020

System Name: SACO RIDGE WATER INC

Pop Served: 80

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200005	BERYLLIUM	MCL VIOLATION	0.00400	0.01770000	01/14/2002	

EPA Id: NH 0162240

System Name: THE SEASONS AT ATTITASH

Pop Served: 440

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
200017	FLUORIDE	MCL VIOLATION	4.00000	4.23300000	05/07/2002	

Description of Data Reported**PWS: Public Water System**

Town: Town, city or unincorporated place - political boundary in which the system is located.

EPA Id: Also known as PWS Id. State and Federal number assigned to track PWS.

System Name: Legal name of PWS.

Pop Served: The population served by PWS.

PWS Type: Type of PWS based on Federal Definition.

Community: Residential system capable of serving at least 25 residents.

Non-Community Non-Transient: Non-residential system capable of serving at least 25 of the same people 6 months a year.

Non-Community Transient: A system capable of serving water to at least 25 people 60 days a year.

Viol Id: The Federal Fiscal Year plus the violation identifier assigned by Environmental Services.

Contaminant: The contaminant and/or rule of which the PWS is in violation.

Violation Description: The type of violation.

Awareness: Date the state became aware of the MCL or TT violation.

MCL (Maximum Contaminant Level): The highest amount of a contaminant that the EPA allows in drinking water. MCLs are defined in milligrams per liter (Mg/l) (parts per million) unless otherwise specified.

Result: Chemical Monitoring (Phase I, II, IIB and V) Rules: The analytical result(s) that caused the MCL violation.

Bacteria (Total Coliform) Rule: PRESENT indicates an MCL violation. ie., coliform is present.

Lead and Copper Rule and Surface Water Treatment Rule: TT (Treatment Technique) Violation or failure to meet operational and/or system requirements under the rule.

Comp Achved: The date the PWS returned to compliance for the violation.

* The violations listed are based on both Env-WS300 "NH Drinking Water Rules" and 40 CFR Part 141-143 "National Primary Drinking Water Regulations, Secondary Drinking Water Regulations"

--- END OF REPORT ---